



## NOTES:

- AERATOR MODEL 700LL MUST BE USED IN CONTINUOUS OPERATION IN EACH TREATMENT CHAMBER
- 2. J-1500 MUST BE PRECEEDED BY 1000 GALLON SEPTIC TANK OR PRETREATMENT TANK
- DEVELOP RISERS TO GRADE OR WITHIN 12\* BELOW GRADE
- 4. PLASTIC RISERS CAST INTO THE TANK LID MAY BE USED IN PLACE OF CONCRETE RISERS

